

Power Systems Technology Center,
a Division of Manitoba Hydro International Ltd.

Harmonizing the Greater Mekong Sub region (GMS) Power Systems to Facilitate Regional Power Trade: Regional Power Master Plan


March 2019

Dharshana Muthumuni (Team Leader)
Bathiya Jayasekara (Power System Specialist)

Outline

- ❑ Background
- ❑ Study Objectives and Methodology
- ❑ Regional Transmission Plan
 - Benefits of cross border power trade
- ❑ Regional Generation and Transmission Plan
 - Preliminary results
- ❑ Conclusions
- ❑ Remaining work and work plan



Background: GMS load demand



- ❑ Greater Mekong Sub (GMS) region has an increasing power demand.
 - Main contributors to the regional load demand are Thailand and Vietnam

Note: China (Yunnan and Guangxi provinces) is modeled as a single node with excess power for export.

Background: GMS renewable generation potential



- ❑ The load and the generation resources in the region are unevenly distributed.
 - Laos, Vietnam, Myanmar and Cambodia have high hydro power potentials whereas Vietnam and Thailand have high wind and solar potential.

Note: Above pie charts show how much hydro and other renewable (wind/ solar) generation is planned to be introduced by year 2030.

Background: Regional Power Trade

Moving towards import or export as a whole region will be economical than considering power development at country level or on bilateral basis. Cross-border regional power trade has several major benefits for the entire region.


- ❑ Improved economic benefit to both power exporters and importers
- ❑ Minimizing Greenhouse Gas (GHG) emission
- ❑ Improvement in the quality and reliability of the regional power system
 - Shared reserves, improved frequency regulation, etc.

Study objectives

Development of the Generation/Transmission Development Master Plan for the power trade in the GMS region.

- ❑ Determine optimal regional generation planning scenarios (for the period from year 2022 to year 2035) based on individual country generation plans.
- ❑ Determine the optimal cross-border power transmission scenarios to facilitate generation plan for the study period from year 2022 to year 2030.
- ❑ Determine and rank most economically and technically feasible cross-border transmission expansions and corresponding regional generation development scenarios.

Study Methodology: Study Process




Study Results

- ❑ Preliminary transmission planning study (Preliminary check of cost savings)
 - Individual country generation plans were used (No further generation planning was performed)
 - Cross border transmission was modeled with each country was modeled with one or few nodes
 - Significant cost savings were identified
- ❑ Generation and transmission planning study
 - Individual country generation plans are modified in generation planning
 - Cross border transmission as well as bulk transmission corridors within the country were adequately modeled

Preliminary transmission planning study

Scenarios

- ❑ Scenario 1 - Base Case (Existing and Under Construction Cross-Border Interconnections)
- ❑ Scenario 2 – With Planned and Proposed Cross Border Transmission Interconnections
- ❑ Scenario 3 - Proposed underutilized interconnections removed
- ❑ Scenario 4 - Increased capacity of the highly utilized interconnections



Existing/Planned and Potential Interconnections


Study Results:

Preliminary transmission planning study

❑ Main outcomes (study year 2025)

Scenario Name	Season	Operational Cost (\$ Billions)	Annual Operational Cost (\$ Billions)
Scenario 1 (Base Case)	Wet	15.2	34.5
	Dry	19.3	
Scenario 2	Wet	13.6	31.0
	Dry	17.4	
Scenario 3	Wet	13.6	31.3
	Dry	17.7	
Scenario 4	Wet	11.1	27.7
	Dry	15.6	


- ❑ Increasing cross-border interconnections reduces the operational cost of the region by \$3.5 -6.8 Billion
- ❑ Further analysis is required to develop power trade master plan




— Under utilized corridors
— Fully Utilized corridors
— Moderately Utilized corridors

Load forecast


Thailand




Vietnam




Myanmar



Laos




Cambodia



Note: Thailand High & low load growth scenarios obtained by scaling the medium load growth data. Cambodia medium & low load growth scenarios are obtained by reducing the high growth scenario.

Load Blocks




Block	1	2	3	4	5	6	7
Hours	(1-6)	(7-9)	(10-13)	(14-16)	(17-18)	(19-21)	(22-24)

- 7 Load blocks are selected to capture load curve characteristics of each country & availability of renewables (day/night)

Regional network model

- ❑ Transmission system model for GMS region
 - More than 650 buses and 1500 lines
 - A complete load flow model (PSS®E)

- ❑ Simplified model for Stochastic Transmission planning (SDDP/OPTNET)
 - Around 200 buses
 - Retain $P-\delta$ characteristics and thermal limits of main corridors






Country	Number of Buses			
	500 kV	230 kV	115<230 kV	Total
Vietnam	53	8	3	64
Thailand	31	109	140	280
Laos	16	35	82	133
Myanmar	2	71	41	114
Cambodia	2	28	31	62
Total	104	251	298	653


Regional network model for generation planning

- ❑ Model for Generation expansion planning (OPTGEN/SDDP)
 - Around 30 buses
 - Retain thermal limits of main transmission corridors

Planned/ Potential generation

Legend:

-  Planned/Potential Hydro
-  Planned/ Potential Solar
-  Planned/ Potential Wind



Generation and transmission planning

Preliminary results


- ❑ Base case
 - Potential generation added based on planning data from individual countries
 - Existing and already planned cross-border interconnections

- ❑ Alternate case 1 (High cross-border transfer)
 - 12 candidate cross-border interconnections are added to base case

- ❑ Alternate case 2 (Low cost of renewable technology)
 - 5 GW and 12 GW of candidate wind/solar generation added to Thailand and Vietnam systems respectively to alternate case 1.


Note: Medium Load growth scenario is used for the analysis

Preliminary results: Regional generation development



- ❑ Generation development in case 1 is less than base case due to better utilization of regional generation using improved cross-border interconnections
- ❑ More renewable generation built in case 2 as expected

Preliminary results: Regional generation development




Base case


Generation and transmission planning

Preliminary results: Generation development in Vietnam

Thermal Generation



Renewable Generation



- ❑ Thermal generation reduced in case1 as imports increase
- ❑ Mainly Laos-Vietnam and China – Vietnam candidate interconnections are selected to be build in optimization for case 1 and case 2
- ❑ Total of about 7 GW of cross-border interconnections were selected in case 1 and case 2

Generation and transmission planning

- ❑ Policy Decisions by individual countries
 - Generation development directions (e.g. high VRE penetration, reduce fossil fuel based generation)
 - Provision of subsidies to certain technologies
- ❑ Historic fuel price/ sale price variation of generation for individual countries
- ❑ Potential cross-border interconnections and power sales prices between countries
- ❑ Box prices for generation/transmission upgrades
- ❑ Additional data on availability of Wind, solar and hydro (seasonal water discharge variation, annual and daily variation of wind solar)

Conclusions

- ❑ Simplified transmission planning studies showed significant benefit in cross-border power trade. This requires further analysis with adequate details of the regional network.
- ❑ A high voltage transmission network model is developed for the GMS region to be used in planning studies.
- ❑ Number of scenarios are identified to capture the uncertainties regarding generation development of the GMS region.
- ❑ Preliminary regional generation and transmission planning studies are carried out for several scenarios with the use of generation plans of individual countries.
 - The generation developments were better utilized with development of cross-border interconnections
 - Lower wind and solar costs would reduce the development of thermal generation

Remaining work

- ❑ Collect additional data to improve the accuracy/uncertainty
- ❑ Complete analysis of critical generation planning scenarios for GMS region
 - Analyze optimized generation planning scenarios and group them for further analysis
 - Identify representative generation planning scenarios to be used in transmission planning
- ❑ Identify credible cross border transmission solutions
 - Identify the most economical and technically feasible transmission scenarios, corresponding upgrades and generation development
- ❑ Verify overall plan using the regional transmission system model (PSS®E)
- ❑ Final study report

Work Plan

	Action	Timeline
1	<p>Send questionnaire to member countries requesting additional data</p> <ul style="list-style-type: none"> <input type="checkbox"/> To improve the accuracy and reduce uncertainties associated with the study results 	April, 2019
2	<p>Visit member counties for discussions</p> <ul style="list-style-type: none"> <input type="checkbox"/> Meet relevant authorities and ADB local representatives <input type="checkbox"/> Gather additional data <input type="checkbox"/> Discuss specific directions/requirements 	May, 2019
3	Preliminary draft report	October, 2019
4	Final draft report	December, 2019

Thank You